

# WIPP Nitrate Salt Bearing Waste Container Isolation Plan Implementation Update

June 11, 2015

## **Panel 6 and Panel 7, Room 7**

### **a. Rollback**

- Contamination Assessment—This prerequisite is complete and therefore status updates are no longer required.
- Fixing/Decontamination Activities—This prerequisite is complete for Panel 6 and Panel 7, Room 7.

### **b. Ground Control Status**

- This prerequisite is complete and therefore status updates are no longer required.

### **c. Habitability**

- This prerequisite is complete and therefore status updates are no longer required.

### **d. Drills, Training, Mockups**

- This prerequisite is complete for Panel 6 and Panel 7, Room 7.

## **Equipment/Ventilation/Materials**

### **a. Electrical**

- Electrical restoration activities required by the Waste Isolation Pilot Plant Nitrate Salt Bearing Waste Container Isolation Plan, Revision 2 is complete; therefore, status updates are no longer required.

### **b. Ventilation**

- Air Flow—The underground ventilation system is operating in filtration mode using one 860 fan that supplies a nominal flow rate of 60,000 standard cubic feet per minute to the underground.

### **c. Stage Needed Materials in Underground/Closure Installation Progress**

- The expedited closure of Panel 6 with the initial closures described in Sections 3.2.2 and 3.3.2 of the Waste Isolation Pilot Plant Nitrate Salt Bearing Waste Container Isolation Plan, Revision 2 is complete; therefore, status updates are no longer required.

# **WIPP Nitrate Salt Bearing Waste Container Isolation Plan Implementation Update**

**June 11, 2015**

- The expedited closure of Panel 7 with the closures described in Sections 3.4.2 and 3.5.2 of the Waste Isolation Pilot Plant Nitrate Salt Bearing Waste Container Isolation Plan, Revision 2 is complete; therefore, status updates are no longer required.

## **Document Preparation**

### **a. Work Planning**

- Work planning documents for Panel 6 initial closure and Panel 7, Room 7 closure are completed therefore status updates are no longer required.

### **b. Safety Basis Documents**

- The safety basis documents that support safety basis authorization for Panel 6 and Panel 7 bulkhead inspection and ground control are completed; therefore, status updates are no longer required.

## **Summary - Information Requests/Status**

None Pending